

Notice of Surface Water Treatment-Technique Violation (Daily)

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

The **City of Big Spring Water Treatment Plant** failed to meet the minimum treatment technique requirements on **01/10/2019**. Specifically, our water system allowed the turbidity of the filtered water to exceed 1.0 Nephelometric Turbidity Units. The City of Big Spring Water Treatment Plant experienced Coagulant equipment failure due to a blockage in the supply line at the Water Treatment Plant.

If you want more information about the nature and significance of this violation, you may contact **Eddie Castillo** at **(432) 264-2501**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Aviso de Violación de Técnicas de Tratamiento de Agua Superficial (Diario)

La Comisión de Calidad Ambiental de Texas (TCEQ) establece normas mínimas de calidad de agua para agua potable pública. Estas normas incluyen requisitos exigibles para técnicas de tratamiento para agua potable. El agua tratada en forma inadecuada puede contener organismos causantes de enfermedades. Estos organismos incluyen bacterias, virus y parásitos que podrían causar síntomas tales como náusea, calambres y diarrea.

El **City of Big Spring Water Treatment Plant** no cumplió con los requisitos técnicos mínimos de tratamiento en **01/10/2019**. Específicamente, nuestro sistema de agua permitió que la turbidez del agua filtrada sobrepasara 1.0 Unidad Nefelométrica de Turbidez.

Si desea más información sobre la naturaleza y el significado de esta violación, puede llamar a **Eddie Castillo** al **(432) 264-2501**.

Por favor comparta esta información con todas las demás personas que toman esta agua, especialmente aquellas que quizás no hayan recibido este aviso directamente (por ejemplo, personas en departamentos, casas de reposo, escuelas y negocios). Puede hacer esto colocando este aviso en un lugar público o distribuyendo copias a mano o por correo.